

**AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT**

1. CONTRACT ID CODE

PAGE OF PAGES

1 1

2. AMENDMENT/MODIFICATION NO.

R0004

3. EFFECTIVE DATE

08/19/04

4. REQUISITION/PURCHASE REQ. NO.

5. PROJECT NO. (If applicable)

6. ISSUED BY CODE

J4P0000

7. ADMINISTERED BY (If other than Item 6)

CODE

W911KB

US ARMY ENGINEER DISTRICT, AK  
CEPOA-CT (W911KB)  
PO BOX 6898  
ELMENDORF AFB, AK 99506-6898

US ARMY ENGINEER DISTRICT, AK  
NORTHERN ALASKA AREA OFFICE  
PO BOX 35066 (BLDG 3025)  
FT WAINWRIGHT, ALASKA 99703-0066

TAMELA PERRY (907)753-5579

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)

(X) 9A. AMENDMENT OF SOLICITATION NO.

X W911KB-04-B-0008

9B. DATED (SEE ITEM 11)

07/20/04

10A. MODIFICATION OF CONTRACT/ORDER NO.

10B. DATED (SEE ITEM 13)

CODE 089C4

FACILITY CODE

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers

is extended,

is not extended.

Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 0 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data (If required)

**PROJECT TITLE AND LOCATION: NEELY ROAD UTILITIES UPGRADE, FT WAINWRIGHT, ALASKA (FTW269)**

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

(X) A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

BID OPENING DATE IS EXTENDED TO 30 AUG 04, 2:00 PM, local time, at the US Army Corps of Engineers-Alaska District, 2204 Third St, Elmendorf AFB, Alaska

**NOTICE TO OFFERORS: PLEASE MARK OUTSIDE OF ENVELOPE IN WHICH BID IS SUBMITTED TO SHOW AMENDMENTS RECEIVED. YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS AMENDMENT ON THE REVERSE SIDE OF STANDARD FORM 1442.**

**IMPORTANT NOTE: Keep in mind that the base is still under tight security measures and access to non-DOD personnel is limited or restricted and requires extra time to process through the Boniface Gate.**

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF SIGNER (Type or print)

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

(Signature of person authorized to sign)

(Signature of Contracting Officer)

***NOTICE TO CONTRACTORS:***

Bidders are advised that at the time of issuance for Amendment 4 to solicitation W911KB-04-B-0008 the Government is not in possession of permits from the Alaska Department of Environmental Conservation (ADEC). It is anticipated that permits will be received on or about August 27, 2004. Bidders are cautioned that award may be delayed or cancelled in the event that permits are not received.

information on the List of Parties Excluded from Federal Procurement and Nonprocurement Programs). The notice must include the following:

- (1) The name of the subcontractor.
- (2) The Contractor's knowledge of the reasons for the subcontractor being on the List of Parties Excluded from Federal Procurement and Nonprocurement Programs.
- (3) The compelling reason(s) for doing business with the subcontractor notwithstanding its inclusion on the List of Parties Excluded from Federal Procurement and Nonprocurement Programs.
- (4) The systems and procedures the Contractor has established to ensure that it is fully protecting the Government's interests when dealing with such subcontractor in view of the specific basis for the party's debarment, suspension, or proposed debarment.

(End of clause)

52.211-10 COMMENCEMENT, PROSECUTION, AND COMPLETION OF WORK (APR 1984)

The Contractor shall be required to

- (a) commence work under this contract with ten (10) calendar days after the date the Contractor receives the notice to proceed,
- (b) prosecute the work diligently, and
- (c) complete the entire work ready for use not later than 30 September 2006, **AM#4**... except for seeding and landscaping of Neely Road, which may be accomplished in the spring of 2007 in accordance with Section 02921, paragraph 3.1.1 ...AM#4

The completion date is based on the assumption that the successful offeror will receive the Notice to Proceed by 27 September 2004. The completion date will be extended by the number of calendar days after the above date that the Contractor receives the Notice to Proceed, except to the extent that the delay in issuance of the Notice to Proceed results from the failure of the Contractor to execute the contract and give the required performance and payment bonds within the time specified in the offer. The time stated for completion shall include final cleanup of the premises.

(End of Clause)

52.211-12 LIQUIDATED DAMAGES--CONSTRUCTION (SEP 2000)

- (a) If the Contractor fails to complete the work within the time specified in the contract, the Contractor shall pay liquidated damages to the Government in the amount of \$1018.00 for each calendar day of delay until the work is completed or accepted.
- (b) If the Government terminates the Contractor's right to proceed, liquidated damages will continue to accrue until

## AMENDMENT 0004 (08/19/04)

### **Sheets C3.20.2, C3.20.3 and C3.20.5 shall be amended as follows:**

A 24" wide by 36" long by 4" deep sump pit shall be made for the new duplex sump pumps and steam ejector (shown on sheets C3.20.2 – "New Steam / Water Plan MH 4-6-1 with Base Bid and Option 1", C3.20.3 – "New Sewer / Condensate Plan MH 4-6-1 with Base Bid and Option 1" and C3.20.5 – "New Steam / Water Plan MH 4-6-1 with Base Bid, but without Option 1" and "New Sewer / Condensate Plan MH 4-6-1 with Base Bid, but without Option 1"). The sump pit shall be made by saw cutting the concrete floor and chipping out the concrete to a depth of 4". The pit shall be centered on the location shown for the duplex sump pumps and steam ejector. A 1" deep by 6" wide channel shall be saw cut and chipped out from the main tunnel drainage channel to the new pit (approximately 7.5 feet long).

The existing 4" steel pipe (shown on sheets C3.20.2 – Section H-H, C3.20.3 – New Sewer / Condensate Plan MH 4-6-1 with Base Bid and Option 1, and C3.20.3 – New Sewer / Condensate Plan MH 4-6-1 with Base Bid, but without Option 1) from the manhole, through into the dry well and then dumping into the wet well shall be removed. The pipe shall be blind flanged or capped and filled with grout at each wall penetration. The existing drainage channel in the manhole (approximately 12" wide by 1" deep by 15 feet long) from the main tunnel to the wall of Building 3724 shall be grouted level with the manhole floor.

The 2-1/2" sump discharge and 4" steam ejector discharge pipes (shown on sheets C3.20.2 – "New Steam / Water Plan MH 4-6-1 with Base Bid and Option 1" and "Section H-H", C3.20.3 – "New Sewer / Condensate Plan MH 4-6-1 with Base Bid and Option 1" and C3.20.5 – "New Steam / Water Plan MH 4-6-1 with Base Bid, but without Option 1" and "New Sewer / Condensate Plan MH 4-6-1 with Base Bid, but without Option 1") shall be changed to turn up after they enter Building 3724, extended up to just under the ceiling (a distance up of approximately 7.5 feet), then turned down (180° turn) and extended back down to the level of the penetration through the wall.

A 4" check valve shall be added in the outlet pipe of the 4" steam ejector pipe in the manhole (shown on sheets C3.20.2 – "New Steam / Water Plan MH 4-6-1 with Base Bid and Option 1" and C3.20.2 – "New Steam / Water Plan MH 4-6-1 with Base Bid and Option 1").

### **Sheet C4.24 shall be amended as follows:**

Change sump pumps for "Typical New Duplex Sump Pump Detail" as follows. The pump capacity shall be changed to a 65 GPM at 30 feet of head submersible sump pump. The motor shall be changed to a 1/2 hp, 115 V, 1 phase, 60 Hz with an electric cord and plug so that it can be connected to a 30 ma GFCI electrical wall outlet on or from the electrical alternator panel. The pump model shall be changed to provide a Zoeller Pump model N3161 sump pumps with electric alternator control panel – for duplex installations or equal.

Change the dimension for the OFF float position (on both details) to be 5" from the sump pit floor.